# Rotary actuator with emergency control function for ball valves

- Nominal torque 2.5 Nm
- · Nominal voltage AC 230 V
- · Control Open-close
- Deenergised open (NO)
- · With integrated auxiliary switch



**Technical data sheet** 

### **Technical data**

lectri		.+-

Nominal voltage	AC 230 V
Nominal voltage frequency	50/60 Hz
Nominal voltage range	AC 85265 V
Power consumption in operation	2.5 W
Power consumption in rest position	1.5 W
Power consumption for wire sizing	5 VA
Auxiliary switch	1 x SPDT, 0100%
Switching capacity auxiliary switch	1 mA3 (0.5 inductive) A, AC 250 V
Connection supply / control	Cable 1 m, 2 x 0.75 mm <sup>2</sup>
Connection auxiliary switch	Cable 1 m, 3 x 0.75 mm <sup>2</sup>
Parallel operation	Yes (note the performance data)
Torque motor	Min. 2.5 Nm
Torque spring return	Min. 2.5 Nm
Divertion of votation environ voture	Decreasional NO value area (A AD 1000/)

#### **Functional data**

Parallel operation	Yes (note the performance data)
Torque motor	Min. 2.5 Nm
Torque spring return	Min. 2.5 Nm
Direction of rotation spring-return	Deenergised NO, valve open (A - AB = 100%)
Manual override	No
Angle of rotation	95°
Running time motor	75 s / 90°
Running time emergency control position	<75 s / 90°
Sound power level motor	50 dB(A)
Position indication	Mechanical
Service life	Min. 60,000 emergency positions
Protection class IEC/EN	II Protective insulated
Protection class auxiliary switch IEC/EN	II Protective insulated

#### Safety

OCIVICE IIIC	wiii. 00,000 emergency positions
Protection class IEC/EN	II Protective insulated
Protection class auxiliary switch IEC/EN	II Protective insulated
Degree of protection IEC/EN	IP42
EMC	CE according to 2004/108/EC
Low voltage directive	CE according to 2006/95/EC
Certification IEC/EN	IEC/EN 60730-1 and IEC/EN 60730-2-14
Mode of operation	Type 1
Rated impulse voltage supply / control	2.5 kV
Rated impulse voltage auxiliary switch	4 kV
Control pollution degree	3
Ambient temperature	-3050°C
Non-operating temperature	-4080°C
Ambient humidity	95% r.h., non-condensing
Maintenance	Maintenance-free
Weight approx.	0.65 kg

## Weight

## Safety notes



- This device has been designed for use in stationary heating, ventilation and air conditioning systems and is not allowed to be used outside the specified field of application, especially in aircraft or in any other airborne means of transport.
- · Caution: Power supply voltage!
- Only authorised specialists may carry out installation. All applicable legal or institutional installation regulations must be complied during installation.
- The device may only be opened at the manufacturer's site. It does not contain any parts that can be replaced or repaired by the user.
- · Cables must not be removed from the device.



## Safety notes

 The device contains electrical and electronic components and is not allowed to be disposed of as household refuse. All locally valid regulations and requirements must be observed.

#### **Product features**

Principle of operation The actuator moves the valve to the operating position at the same time as tensioning

the return spring. The valve is turned back to the emergency position by spring force

when the supply voltage is interrupted.

Simple direct mounting Simple direct mounting on the ball valve with only one screw. The mounting orientation

in relation to the ball valve can be selected in 90° steps.

High functional reliability 
The actuator is overload protected, requires no limit switches and automatically stops

when the end stop is reached.

Flexible signalization With adjustable auxiliary switch (0 ... 100%)

#### **Electrical installation**




**Notes** 

- · Caution: Power supply voltage!
- · Parallel connection of other actuators possible. Observe the performance data.

### Wiring diagrams

AC 230 V, open-close



#### Cable colours:

1 = blue

2 = brown


S1 = violet

S2 = red

S3 = white

## Dimensions [mm]

## **Dimensional drawings**



#### **Further documentation**

- · Overview Valve-actuator combinations
- · Data sheets for ball valves
- · Installation instructions for actuators and/or ball valves
- · General notes for project planning